

CERTIFICATE OF ANALYSIS

Work Order : **EW1904933**
Client : **WOLLONGONG CITY COUNCIL**
Contact : DELLA KUTZNER
Address : 41 BURELLI STREET
 WOLLONGONG NSW, AUSTRALIA 2500

Telephone : +61 02 4227 7111
Project : Helensburgh Groundwater Quarterly
Order number : 1011047
C-O-C number : ----
Sampler : Robert DaLio
Site : ----
Quote number : WO/005/18 TENDER
No. of samples received : 8
No. of samples analysed : 8

Page : 1 of 4
Laboratory : Environmental Division NSW South Coast
Contact : Glenn Davies
Address : 1/19 Ralph Black Dr, North Wollongong 2500
 4/13 Geary Pl, North Nowra 2541
 Australia NSW Australia
Telephone : 02 42253125
Date Samples Received : 13-Nov-2019 15:20
Date Analysis Commenced : 12-Nov-2019
Issue Date : 20-Nov-2019 12:16



Accreditation No. 825
 Accredited for compliance with
 ISO/IEC 17025 - Testing

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Accreditation Category</i>
Ankit Joshi	Inorganic Chemist	Sydney Inorganics, Smithfield, NSW
Celine Conceicao	Senior Spectroscopist	Sydney Inorganics, Smithfield, NSW
Dian Dao		Sydney Inorganics, Smithfield, NSW
Glenn Davies	Environmental Services Representative	Laboratory - Wollongong, NSW



General Comments

The analytical procedures used by the Environmental Division have been developed from established internationally recognized procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are employed in the absence of documented standards or by client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Key : CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.
LOR = Limit of reporting
^ = This result is computed from individual analyte detections at or above the level of reporting
ø = ALS is not NATA accredited for these tests.
~ = Indicates an estimated value.



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)				Client sample ID				
Client sampling date / time				BH1	BH4	BH5 GWMB5	BH6 GWMB6	LGMB1
Compound				12-Nov-2019 12:30	12-Nov-2019 10:20	12-Nov-2019 13:00	12-Nov-2019 10:05	12-Nov-2019 12:50
CAS Number	LOR	Unit	EW1904933-001	EW1904933-002	EW1904933-003	EW1904933-004	EW1904933-005	
			Result	Result	Result	Result	Result	
EA005FD: Field pH								
pH	----	0.1	pH Unit	4.5	----	4.2	6.9	5.0
EA015: Total Dissolved Solids dried at 180 ± 5 °C								
Total Dissolved Solids @180°C	----	1	mg/L	749	----	102	366	154
ED037P: Alkalinity by PC Titrator								
Hydroxide Alkalinity as CaCO3	DMO-210-001	1	mg/L	<1	----	<1	<1	<1
Carbonate Alkalinity as CaCO3	3812-32-6	1	mg/L	<1	----	<1	<1	<1
Bicarbonate Alkalinity as CaCO3	71-52-3	1	mg/L	4	----	3	325	28
Total Alkalinity as CaCO3	----	1	mg/L	4	----	3	325	28
ED041G: Sulfate (Turbidimetric) as SO4 2- by DA								
Sulfate as SO4 - Turbidimetric	14808-79-8	1	mg/L	146	----	23	<1	56
ED045G: Chloride by Discrete Analyser								
Chloride	16887-00-6	1	mg/L	282	----	36	17	18
ED093T: Total Major Cations								
Calcium	7440-70-2	1	mg/L	65	----	5	72	11
Magnesium	7439-95-4	1	mg/L	41	----	4	40	7
Sodium	7440-23-5	1	mg/L	109	----	26	22	25
Potassium	7440-09-7	1	mg/L	<1	----	1	4	<1
EK055G: Ammonia as N by Discrete Analyser								
Ammonia as N	7664-41-7	0.01	mg/L	0.02	----	<0.01	<0.01	<0.01
EN67 PK: Field Tests								
Field Observations	----	0.01	--	----	blocked	----	----	----
EP005: Total Organic Carbon (TOC)								
Total Organic Carbon	----	1	mg/L	3	----	<1	12	2
FWI-EN/001: Groundwater Sampling - Depth								
Depth	----	0.01	m	4.00	----	4.63	3.41	2.68



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)				Client sample ID	LGMB2	LGMB3	LGMB4	----	----
Client sampling date / time				12-Nov-2019 12:20	12-Nov-2019 11:40	12-Nov-2019 12:00	----	----	
Compound	CAS Number	LOR	Unit	EW1904933-006	EW1904933-007	EW1904933-008	-----	-----	
				Result	Result	Result	----	----	
EA005FD: Field pH									
pH	----	0.1	pH Unit	4.9	4.8	4.5	----	----	
EA015: Total Dissolved Solids dried at 180 ± 5 °C									
Total Dissolved Solids @180°C	----	1	mg/L	98	78	126	----	----	
ED037P: Alkalinity by PC Titrator									
Hydroxide Alkalinity as CaCO3	DMO-210-001	1	mg/L	<1	<1	<1	----	----	
Carbonate Alkalinity as CaCO3	3812-32-6	1	mg/L	<1	<1	<1	----	----	
Bicarbonate Alkalinity as CaCO3	71-52-3	1	mg/L	14	9	5	----	----	
Total Alkalinity as CaCO3	----	1	mg/L	14	9	5	----	----	
ED041G: Sulfate (Turbidimetric) as SO4 2- by DA									
Sulfate as SO4 - Turbidimetric	14808-79-8	1	mg/L	27	18	34	----	----	
ED045G: Chloride by Discrete Analyser									
Chloride	16887-00-6	1	mg/L	12	15	14	----	----	
ED093T: Total Major Cations									
Calcium	7440-70-2	1	mg/L	11	8	9	----	----	
Magnesium	7439-95-4	1	mg/L	4	2	2	----	----	
Sodium	7440-23-5	1	mg/L	10	12	10	----	----	
Potassium	7440-09-7	1	mg/L	4	4	22	----	----	
EK055G: Ammonia as N by Discrete Analyser									
Ammonia as N	7664-41-7	0.01	mg/L	0.01	0.16	<0.01	----	----	
EP005: Total Organic Carbon (TOC)									
Total Organic Carbon	----	1	mg/L	2	1	3	----	----	
FWI-EN/001: Groundwater Sampling - Depth									
Depth	----	0.01	m	3.62	3.38	3.72	----	----	